

Certificate



No.: 968/FSP 1064.04/20

Product tested	Quartz™ Valve Position Indicator/Sensor	Certificate holder	Neles USA Inc. dba StoneL 26271 US Highway 59 Fergus Falls, MN 56537 USA
Type designation	QX- and QN- Models (Details see Appenix of Certificate)		
Codes and standards	IEC 61508 Parts 1-7:2010 (in extracts)		
Intended application	<p>The Quartz™ Valve Position Indicator/Sensor can be used in a safety instrumented system (SIS) as sensor(s) to indicate the position of a valve assembly.</p> <p>Some variants listed on the next pages can be used in applications up to SIL 3 acc. to IEC 61508 and IEC 61511-1. The configuration and number of switches (HFT = 0 or 1) depend on the target safety level (SIL) and the evaluation of the signals in the safety controller.</p> <p>Other variants listed on the next pages are not available in a redundant configuration. Due to this fact the hardware fault tolerance is 0 (HFT=0) and considering the achieved SFF of < 90 %, the devices fulfil the requirements for the hardware integrity of SIL 2 of IEC 61511-1, table 6 and IEC 61508-2, table 2.</p>		
Specific requirements	The instructions of the associated Installation, Maintenance and Operating Instructions and Safety Manual shall be considered.		

Valid until 2025-07-03

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 1064.04/20 dated 2020-07-03.
This certificate is valid only for products which are identical with the product tested.

Köln, 2020-07-03

Certification Body Safety & Security for Automation & Grid

Dr.-Ing. Thorsten Gantevoort

Safety function: Sensing of the position of valves or actuators. The configuration and number of switches (HFT = 0 or 1) depend on the target safety level (SIL) up to SIL 3 and the evaluation of the signals in the safety controller.

Opening and closing position of the switches may be configured such that an open contact results to an action into the safe direction of the SIF.

Model Series	Type	λ / 1/h	λ_s / 1/h	λ_d / 1/h	SFF
QX2J, QX4J, QX5J, QX7J QN2J, QN4J, QN5J, QN7J	A	9.93E-09	8.27E-09	1.66E-09	83,3%
QX2L, QX4L, QX5L, QX7L QN2L, QN4L, QN5L, QN7L	A	1.97E-08	1.23E-08	7.38E-09	62,4%
QX2P, QX4P, QX5P, QX7P QN2P, QN4P, QN5P, QN7P	A	9.93E-09	8.27E-09	1.66E-09	83,3%
QX2G, QX4G, QX5G, QX7G QN2G, QN4G, QN5G, QN7G	A	9.93E-09	8.27E-09	1.66E-09	83,3%
QX2H, QX4H, QX5H, QX7H, QX8H QN2H, QN4H, QN5H, QN7H, QN8H,	A	9.93E-09	8.27E-09	1.66E-09	83,3%
QX2M, QX4M, QX5M, QX7M, QN2M, QN4M, QN5M, QN7M	A	9.93E-09	8.27E-09	1.66E-09	83,3%
QX2S, QX4S, QX5S, QX7S QN2S, QN4S, QN5S, QN7S	A	1.97E-08	1.23E-08	7.38E-09	62,4%
QX4X, QX6X, QN4X, QN6X	A	1.60E-07	9.34E-08	6.62E-08	58,4%
QX2A, QX4A, QX5A, QX7A, QN2A, QN4A, QN5A, QN7A	A	2.97E-08	1.91E-08	1.07E-08	64,4%
QX2N, QX4N, QX5N, QX6N, QX7N QN2N, QN4N, QN5N, QN6N, QN7N	A	2.90E-08	2.21E-08	6.91E-09	76,2%
QX33, QN33	A	2.73E-07	1.64E-07	1.10E-07	60,1%
QX44, QN44	A	2.02E-07	1.35E-07	6.78E-08	66,8%

λ Total Failure Rate ($\lambda = \lambda_s + \lambda_d$)

λ_s Safe Failure Rate

λ_d Dangerous Failure Rate

Safe Failure Fraction SFF = λ_s / λ

Safety function: Sensing of the position of valves or actuators and translating it into a 4-20mA value. Certified up to SIL 2, see note below.

Diagnostic measures: For the calculation of the safety related reliability data it is assumed that the safety controller has to perform the following diagnostic measures:
 In case the current <3mA or >21mA the safety controller has to perform a safety related action.

Model Series	λ / 1/h	λ_s / 1/h	λ_d / 1/h	λ_{dd} / 1/h	λ_{du} / 1/h	SFF
QN50, QX50	1,36E-07	2,84E-08	1,07E-07	7,03E-08	3,69E-08	72,8 %
QN70, QX70	1,31E-07	2,84E-08	1,03E-07	6,65E-08	3,64E-08	72,3 %

λ total failure rate

λ_d Current deviates more than 20% from the "real" value (valve Position)

λ_s Current deviates less than 20% from the "real" value (valve Position)

λ_{dd} Current is <3mA or >21mA

λ_{du} Current deviates more than 20% from the "real" value (valve Position), but is still within 3 to 21mA

Safe Failure Fraction SFF = $(\lambda - \lambda_{du}) / \lambda$

Note: The models listed in the table above are not available in a redundant configuration. Due to this fact the hardware fault tolerance is 0 (HFT=0) and considering the achieved SFF, which is smaller than 90%, the devices fulfil the requirements for the hardware integrity up to SIL 2 of IEC 61511-1, table 6 and IEC61508-2, table 2.

Safety function: Sensing of the position of valves or actuators and translating it into a 0-10kOhm resistance value. Certified up to SIL 2, see note below.

Diagnostic measures: For the calculation of the safety related reliability data it is assumed that the safety controller has to perform the following diagnostic measures:
In case the resistance is > 11kOhm the safety controller has to perform a safety related action.

Model Series	λ / 1/h	λ_s / 1/h	λ_d / 1/h	λ_{dd} / 1/h	λ_{du} / 1/h	SFF
QNBO, QXBO	3,80E-08	3,50E-09	3,45E-08	3,04E-08	4,10E-09	89,2%
QNCO, QXCO	3,37E-08	3,07E-09	3,06E-08	2,70E-08	3,67E-09	89,1%

λ total failure rate

λ_d Resistance deviates more than 20% from the "real" value (valve Position)

λ_s Resistance deviates less than 20% from the "real" value (valve Position)

λ_{dd} Resistance is >11kOhm

λ_{du} Resistance deviates more than 20% from the "real" value (valve Position), but is still below 11kOhm

Safe Failure Fraction SFF = $(\lambda - \lambda_{du}) / \lambda$

Note: The models listed in the table above are not available in a redundant configuration. Due to this fact the hardware fault tolerance is 0 (HFT=0) and considering the achieved SFF, which is smaller than 90%, the devices fulfil the requirements for the hardware integrity up to SIL 2 of IEC 61511-1, table 6 and IEC61508-2, table 2.

Safety function: Sensing of the position of valves or actuators. Certified up to SIL 2.

Model Series	λ / 1/h	λ_s / 1/h	λ_d / 1/h	λ_{dd} / 1/h	λ_{du} / 1/h	SFF
QN35, QX35	2,24E-07	1,40E-07	8,40E-08	0	8,40E-08	62,5%
QN45, QX45	3,55E-07	2,43E-07	1,11E-07	0	1,11E-07	68,6%