

Certificate



No.: 968/FSP 2194.00/21

Product tested	Hawkeye™ Valve Position Monitors	Certificate holder	Neles USA Inc. dba StoneL 26271 US Highway 59 Fergus Falls, MN 56537 USA
-----------------------	----------------------------------	---------------------------	---

Type designation	HX / HK (Details see Revision List)
-------------------------	--

Codes and standards	IEC 61508 Parts 1-7:2010
----------------------------	--------------------------

Intended application	The Hawkeye™ valve position monitors can be used in a safety instrumented system (SIS) as sensor(s) to indicate the position of a valve assembly. The sensors fulfill the requirements of SIL 2, SC 3 according to IEC 61508 and can be used in applications as such.
-----------------------------	---

The product was also reviewed in reference to the requirements of IEC 61511-1:2016 + Corr.1:2016 + AMD1:2017 applicable during a type examination and can be used in application as such.

Specific requirements	The instructions of the associated Installation, Maintenance and Operating Instructions and Safety Manual shall be considered.
------------------------------	--

Valid until 2026-02-11

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 2194.00/21 dated 2021-02-08.

This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2021-02-11

Certification Body Safety & Security for Automation & Grid


Dipl.-Ing. Gebhard Bouwer